

Capacity	Unit	Mfct/Model #	Services	Equipment	Location	#of Filters	Filter Size	Filter Type	Belt Size	#of Belts	Motor HP
28,000	S1	MCQUAY/MSL-164BH	Upper East end of Bowl	Heat/Cool	Upper East end of Bowl	36	20x25x2	MERV 8	CP173	3	30
34,000	S2	MCQUAY/MSL-164BH	SE Bowl	Heat/Cool	101 Fan Room	36	20x25x2	MERV 8	CP173	3	30
32,700	S3	MCQUAY/MSL-164BH	West End of Upper Bowl	Heat/Cool	West End of Upper Bowl	36	20x25x2	MERV 8	BP180	4	15
34,000	S4	MCQUAY/MSL-164BH	SW Bowl	Heat/Cool	107 Concourse	36	20x25x2	MERV 8	CP173	3	30
32,700	S5	MCQUAY/MSL-164BH	West End of Upper Bowl	Heat/Cool	West End of Upper Bowl	36	20x25x2	MERV 8	BP180	4	15
33,500	S6	MCQUAY/MSL-164BH	NW Bowl	Heat/Cool	112 Fan Room	36	20x25x2	MERV 8	CP173	3	30
28,000	S7	MCQUAY/MSL-164BH	Upper East end of Bowl	Heat/Cool	Upper East end of Bowl	36	20x25x2	MERV 8	BP180	4	15
33,500	S8	MCQUAY/MSL-164BH	NE Bowl & Club	Heat/Cool	117 Fan room	36	20x25x2	MERV 8	CP173	3	30
16,350	S9	MCQUAY/MSL-228CH	SE Concourse	Heat/Cool	South Mechanical Room	12	20x20x2	MERV 8	BP93	4	25
11,650	S10	MCQUAY/MSL-228CH	SW Concourse	Heat/Cool	South Mechanical Room	12	20x20x2	MERV 8	-	4	25
15,850	S11	MCQUAY/MSL-228CH	North Concourse	Heat/Cool	Mezz above Dressing	12	20x20x2	MERV 8	BP82	3	20
16,350	S12	MCQUAY/MSL-228CH	North Concourse	Heat/Cool	Mezz above Dressing	12	10x20x2	MERV 8	BP82	3	20
14,810	S13	MCQUAY/MSL-220CH	WP Weight Room/MR 1&2	Heat/Cool	South Mechanical Room	10	20x20x2	MERV 8	BP100	3	15
8,755	S14	MCQUAY/MSL-220CH	Locker Room	Heat/Cool	Chiller Room	10	16x25x2	MERV 8	BP70	2	25
24,250	S15	MCQUAY/PSL-150	Low Mez/Upper Mez	Heat/Cool	South Mechanical Room	18	20x25x2	MERV 8	BP144	4	30
	S16	MCQUAY/MSL-150BH	Truck Route	Heat/Cool	South Mechanical Room	18	20x25x2	MERV 8	BP144	4	30
24,250	S17	MCQUAY/MSL-150BH	West Hall	Heat/Cool	South Mechanical Room	8	20x20x2	MERV 8	BP144	4	30
21,500	S18	MCQUAY	Assembly Hall	Heat/Cool	Corner of East Hall/Behind Admin	32	20x24x2	MERV 8	BP173	4	25
5,150	S19	MCQUAY/MSL-111CV	Admin	Heat/Cool	Behind Admin	6	10x20x2	MERV 8	BP78	2	7.5
27,400	S20	TRANE/CSAA57	East /Assembly Hall/Truck Route	Heat/Cool	Corner of East Hall	24	20xx20x2	MERV 8	BP162	4	20
46,800	S21	TRANE CC M-86-B	Concourse and Upper West End	Heat/Cool	West End	42	20x25x2	MERV 8	BP99	3	15
46,800	S22	TRANE CC M-86-B	Concourse and Upper West End	Heat/Cool	West End	42	20x25x2	MERV 8	-	-	15
13,050	S23	TRANE CC M-12-B	Room A200	Heat/Cool	Mer A-500	8	20x25x2	MERV 8	BP99	3	15
13,050	S24	TRANE CC M-12-B	RoomB200	Heat/Cool	Mer B-500	8	20x25x2	MERV 8	-	-	15
	S26	-	Grill stand/back hallway	Heat/Cool	Above Grill Stand			MERV 8	-	-	-
5,000	MZU1	MCQUAY/LML-111EH	Suite Lobby, Directors Suite, Boardroom	Heat/Cool - not chilled water	Penthouse	6	20x25x2	MERV 8			25
5,000	MZU2	MCQUAY/LML-111EX	Kitchen, 100 Storage Level	Heat/Cool	Penthouse	8	20x25x2	MERV 8			25
5,000	MU1	MCQUAY/LML111CH	Make up unit for Rangehood		Penthouse	6	20x25x2	MERV 8			25
3,300	AHU1	MCQUAY/LSL-122DH	Comcast Club	Heat/Cool - not chilled water	Catwalk Above Kitchen	10	20x25x2	MERV 8			20
5,000	AHU1	TRANE CCDB10	Home Locker Room		WolfPack Mer	6	20x25x2	MERV 8			25

Unit	Services	Equipment	Location	Belt Size	#of Belts	Motor HP
R1	Upper East end of Bowl	Return	Upper East end of Bowl	BP112	3	30
R2	SE Bowl	Return	101 Fan Room	BP112	3	30
R3	West End of Upper Bowl	Return	West End of Upper Bowl	BP112	3	30
R4	SW Bowl	Return	107 Concourse	BP112	3	30
R5	West End of Upper Bowl	Return	West End of Upper Bowl	BP112	3	30
R6	NW Bowl	Return	112 Fan Room	BP112	3	30
R7	Upper East end of Bowl	Return	Upper East end of Bowl	BP112	3	30
R8	NE Bowl & Club	Return	117 Fan room	BP112	3	30
R9	SE Concourse	Return	South Mechanical Room	BP78	2	7.5
R10	SW Concourse	Return	South Mechanical Room	BP78	2	7.5
R11	North Concourse	Return	Mezz above Dressing	BP78	2	7.5
R12	North Concourse	Return	Mezz above Dressing	BP82	2	20
R13	WP Weight Room/MR 1&2	Return	South Mechanical Room	BP40	2	15
R14	Locker Room	Return	Chiller Room			25
R15	Low Mez/Upper Mez	Return	South Mechanical Room	BP195	3	30
R16	Truck Route	Return	South Mechanical Room	BP180	4	30
R17	West Hall	Return	South Mechanical Room	BP173	4	30
R18	Assembly Hall	Return	Corner of East Hall/Behind Admin	BP195	4	25
R19	Admin	Return	Behind Admin	BP82	2	7.5
R20	East /Assembly Hall/Truck Route	Return	Corner of East Hall	BP173	3	20
R21	Concourse and Upper West End	Return	West End			15
R22	Concourse and Upper West End	Return	West End			15
R23	Room A200	Return	Mer A-500	BP99	3	2
R24	RoomB200	Return	Mer B-500			2
R26	Grill stand/back hallway	Return	Above Grill Stand			-

EXHAUST

150	EF 1-01	CSP-A250	West Show Power Room	Exhaust	Show Power RM	INLINE	83
500	EF 1-02	BSQ-80	Emergency Elec Room	Exhaust	EM Elect RM	INLINE	0.25
920	EF 1-03	BSQ130HP	Emergency Elec Room	Exhaust	EM Elect RM	INLINE	1.5
4,800	GEF 7-01	BISW-20	Kitchen Grease Hood	Exhaust	Roof	UTILITY SET	5
12,500	SEF 6-01	GREENHECK/AX103	New Upper Con Smoke Exhaust	Exhaust	Node Roof	UP-BLAST	5
25,000	SEF 6-02	GREENHECK/AX123	NW Node Smoke Exhaust	Exhaust	Node Roof	UP-BLAST	5
6,250	SEF 6-03A	GREENHECK/AX-54	NW Node Smoke Exhaust	Exhaust	L61 Ceiling	INLINE	1.5
6,250	SEF 6-03B	GREENHECK/AX-54	NW Node Smoke Exhaust	Exhaust	L61 Ceiling	INLINE	1.5
6,250	SEF 6-03C	GREENHECK/AX-54	NW Node Smoke Exhaust	Exhaust	L61 Ceiling	INLINE	1.5
6,250	SEF 6-03D	GREENHECK/AX-54	NW Node Smoke Exhaust	Exhaust	L61 Ceiling	INLINE	1.5
6,250	SEF 6-03E	GREENHECK/AX-54	NW Node Smoke Exhaust	Exhaust	L61 Ceiling	INLINE	1.5
6,250	SEF 6-03F	GREENHECK/AX-54	NW Node Smoke Exhaust	Exhaust	L61 Ceiling	INLINE	1.5
12,500	SEF 6-04	GREENHECK/AX-80	NE Upper Con Smoke Exaust	Exhaust	L83 Mech Room	INLINE	5
12,500	SEF 6-05	GREENHECK/AX-103	SE Upper Con Smoke Exaust	Exhaust	Node Roof	UP-BLAST	5
25,000	SEF 6-06	GREENHECK/AX-123	SE Node Smoke Exhaust	Exhaust	Node Roof	UP-BLAST	5
25,000	SEF 6-07	GREENHECK/AX-124	SW Node Smoke Exhaust	Exhaust	Node Roof	UP-BLAST	5
12,500	SEF 6-08	GREENHECK/AX-103	SW Upper Con Smoke Exhaust	Exhaust	Node Roof	UP-BLAST	5
25,000	SEF 7-01	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5
25,000	SEF 7-02	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5
25,000	SEF 7-03	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5
25,000	SEF 7-04	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5
25,000	SEF 7-05	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5
25,000	SEF 7-06	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5
25,000	SEF 7-07	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5
25,000	SEF 7-08	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5
25,000	SEF 7-09	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5
25,000	SEF 7-10	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5
25,000	SEF 7-11	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5
25,000	SEF 7-12	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5
25,000	SEF 7-13	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5
25,000	SEF 7-14	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5
25,000	SEF 7-15	GREENHECK/AX-123	Bowl Smoke Exhaust	Exhaust	Roof	UP-BLAST	5

Roof Top Unit

16,000	RTU6	TRANE/TCH480	Rooftop unit/Suites	Cooling Only/Ventilation	Roof	MERV-8	15
3,250	AHU1-1	TRANE/CSAA-8	Uconn Hockey	Heat/Cool/Ventilation	South Mechanical Room	MERV-8	5

Split System Air

1201	Mitsubishi	MITSUBISHI/PEAD-A36AA4	L31 Sound Room	Split Air	Above Visting LR's
640	Mitsubishi	MITSUBISHI/PLA-A2BA4	L31 Video Room	Split Air	Above Visting LR's
640	Mitsubishi	MITSUBISHI/PLA-A24BA4	L31 Video Room	Split Air	Above Visting LR's
775	Mitsubishi	MITSUBISHI/PKA-A24KA4	L48 Headend Room	Split Air	Above Visting LR's

Carrier Units

2706	CARRIER	50GS-030-501	Visiting LR's		Above Visting LR's	0.09
2170	CARRIER	50YH030500	Visiting LR's		Above Visting LR's	0.09
2170	CARRIER	50YH030500	Visiting LR's		Above Visting LR's	0.09

Condensing Unit

CU 1-1	MITSUBISHI/PUY-A36NHA4	L31 Sound Room	Split Air	Lee McGinley
CU 1-2	MITSUBISHI/PUY-A24NHA4	L31 Video Room	Split Air	Lee McGinley
ACU 1-1	MITSUBISHI/PUY-A24NHA5	L31 Video Room	Split Air	Truck Route
ACU 1-2	MITSUBISHI/PUY-A24NHA6	L48 Headend Room	Split Air	Truck Route

Cabinet Heater

400	3-1 Trane	TRANE/FFE04	Concession #3	Cabinet Unit Heater	
400	3-2 Trane	TRANE/FFE05	Concession #4	Cabinet Unit Heater	
	FCU-1	TTA072C400A0	Wolf Pack LR	Air Conditioning	Outside Shipping & Receiving
	FCU-2	2TTA0072A4000AA	Wolf Pack LR	Air Conditioning	Outside Shipping & Receiving

Ventilation

	Belt Size	# Of Belts	Location	Services		
V-1	BP255	4	Above Engineer Shop	Back of House	BP255	4
V-2	BP144	2	South Mechanical Room	South Mechanical Room	BP144	2
V-3	BP70	2	Chiller Room	Chiller Room	BP70	2
V-4	BP58	2	Valve Room	Valve Room	BP58	2
V-5	BP195	4	Generator Room	Generator Room	BP195	4
V-6	BP90	2	Admin Mechanical	Admin Mechanical	BP90	2
V-7	A36		Switch Gear Room	Switch Gear Room	A36	